



The conductor curve shown is that used for determining tower locations Datum: USG & GS Cond: ACSR DRAKE — MWT 8000 at 1/2" ICE		UNITED STATES DEPARTMENT OF THE INTERIOR BONNEVILLE POWER ADMINISTRATION PAUL J. RAVER, ADMINISTRATOR	
McNARY - PENDLETON LINE 230 KV SINGLE CIRCUIT TRANSMISSION LINE MILE 17 FROM McNARY		Designed: FWF Drawn: FWM Traced: VCL Checked: MSH	
APPROVED: [Signature] DATE: 11-3-50		Approved: [Signature] DATE: 11-3-50	
SHEET 17 OF 40		51117	
FOR CONSTRUCTION		133-01-340-D1	