

**Ordnance Multi-Use Water Project**

**ITB-007 Requests for Information (RFI)**

**3/15/23**

1. RFI #1 – Confirming the steel pipe section Part 2, 2.1 in ITB-007 is the casing pipe specification?
  - a. RFI #1 Response – Steel casing pipe shall be ASTM A139 Grade B or equivalent.
2. RFI #2 – We typically do not hydro test casing pipe due to it being non-pressurized. Confirming this is accurate?
  - b. RFI #2 Response – Yes, there is no requirement for hydro testing the steel casing pipe.
3. RFI #3 – Request using a standard 36ksi yield instead of high yield 52ksi. This is non-pressurized pipe. We typically do not see a high yield material as a determination for casing pipe. Still use the same wall thickness.
  - c. RFI #3 Response – 36ksi yield strength is acceptable for the steel casing pipe. Steel casing pipe shall have a minimum yield strength of 35,000psi.